

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 7150-0082:111 Page 1 of 1

CATEGORY: Pull Station/Boxes

LISTEE: Rauland-Borg Corp., 3450 W. Oakton Street, Skokie, IL 60076
Contact: Daryl Miceli (708) 679-0900

DESIGN: Model FAR410, non-coded, manual pull station. Unit consists of a listed Federal Signal's Model 4050-001T pull station (CSFM Listing No. 7150-0811:115) with a limiting series resistor for compatibility with listee's listed Model FA 3002 SecurePlex AS fire alarm control unit. Refer to listee's data sheet for additional detailed product description and operational considerations.

RATING: 22.6 VDC

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, product number, electrical rating and UL label.

APPROVAL: Listed as manual pull station for use only with Model FA 3002 SecurePlex AS (CSFM Listing No. 7165-0082:103) fire alarm control unit. Unit shall be mounted on a listed outlet box. For indoor use only.

07-12-96



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued:

JUNE 8, 2002

*Listing Expires **June 30, 2003***

Authorized By:

DIANE K. AREND, Senior Deputy
Program Manager